



- 註: 1. 本基礎台及尺寸, 僅供客戶固定基礎螺栓施作參考.  
2. 基礎台高度之平面, 水平公差為 $\pm 2\text{mm}$ .  
3. 基礎台高度不包含保溫層及防水層.  
4. 若需安裝避震器及防震鐵架, 基礎施作注意事項, 請洽本公司業務人員.  
5. (\*) 設計基礎台高度, 可依主管管徑調整高度.

REMARK:

1. THIS FOUNDATION DRAWING IS FOR REFERENCE TO POSITION THE ANCHOR BOLTS WITHOUT ISOLATORS (SPRING MOUNTS).  
2. THE LEVEL TOLERANCE OF FOUNDATION IS  $\pm 2\text{mm}$ .  
3. THE HEIGHT OF FOUNDATION EXCLUDES THERMAL ISOLATOR AND WATER PROOF.  
4. THIS DRAWING IS FOR NON-ISOLATOR TYPE FOUNDATION, FOR ISOLATOR TYPE FOUNDATION, PLEASE CONTACT YOUR LOCAL SALES ENGINEER FOR DETAILS.  
5. (\*) THE DESIGN OF FOUNDATION HEIGHT CAN BE ADJUSTED ACCORDING TO THE DIAMETER OF MAINPIPE.

137-01  
B-TR1036C-C4.DWG

變更號碼	日期	變更	校對	核准	記 事 NOTE		
圖 名 TITLE	LCTR-1036C-C4						
	基礎圖 FOUNDATION						
核定	蕭健明				MM	1 / 150	107.01.11
校對	潘信安		製圖	陳彥鈞	圖	號	DWG NO.
良機實業股份有限公司 LIANG CHI INDUSTRY CO., LTD.					91-174-9266		

A8-3-44